

2022 CONSUMER CONFIDENCE REPORT CONEHATTA PUBLIC WATER SYSTEM

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Your water comes from an underground source. We pump water from two (2) wells that are over 600 feet deep. The underground water source that we pump from is called the Wilcox Aquifer. Once the water is pumped to the surface, chlorine and fluoride are added before it is sent out to the community water lines for use.

Source Water Assessment

If you are interested in more information about where your water comes from, we can arrange for you to review or to get a copy of our Source Water Assessment Report. Call Choctaw Utilities at (601) 650-1760 to discuss your information needs.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

2022 CONSUMER CONFIDENCE REPORT CONEHATTA PUBLIC WATER SYSTEM

- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Choctaw Utilities is honored that you allow us to operate YOUR water system. We view our customers as partners in our efforts to provide safe drinking water. Help us protect our water system from contamination by remembering these tips: never submerge a free running hose in water and never leave a hose submerged in standing water; never use a hose connected to your faucet to spray toxic chemicals (such as pesticides or lawn treatments); and always report leaking septic tanks, manholes, pump stations, or sewer lines to Choctaw Utilities. These are all potential contamination sources that could affect our water supply. Also, help us control your water costs by promptly reporting line breaks or damaged equipment such as fire hydrants, storage tanks, etc. to us at (601) 650-1760.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference. Try one today and soon it will become second nature.

- Take short showers. A 5-minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair, and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They are inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!

- Visit www.epa.gov/watersense for more information.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Conehatta Water System is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminant	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
			Low	High			
Conehatta LRAA #3 - Disinfection Byproducts							
Haloacetic Acids	<60.0 ppb	3.4 ppb	NA		9/29/22	No	Byproduct of drinking water disinfection
Total Trihalomethanes	<80.0 ppb	8.4 ppb	NA		9/27/22	No	Byproduct of drinking water disinfection
Conehatta LRAA #4 - Disinfection Byproducts							
Haloacetic Acids	<60.0 ppb	5.2 ppb	NA		9/29/22	No	Byproduct of drinking water disinfection
Total Trihalomethanes	<80.0 ppb	9.3 ppb	NA		9/27/22	No	Byproduct of drinking water disinfection

2022 CONSUMER CONFIDENCE REPORT CONEHATTA PUBLIC WATER SYSTEM

Contaminant	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
			Low	High			
Lead and Copper							
90 th Percentile (Lead) Jan-June	15 ppb	0.81 ppb	0 Sites over action level		Feb. 2022	No	Corrosion of household plumbing systems; Erosion of natural deposits
90 th Percentile (Copper) Jan-June	1,300 ppb	430 ppb	0 Sites over action level		Feb. 2022	No	Corrosion of household plumbing systems; Erosion of natural deposits
90 th Percentile (Lead) July-Dec	15 ppb	.94 ppb	0 Sites over action level		July – Dec. 2022	No	Corrosion of household plumbing systems; Erosion of natural deposits
90 th Percentile (Copper) July-Dec	1,300 ppb	670 ppb	0 Sites over action level		July – Dec. 2022	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated



2022 CONSUMER CONFIDENCE REPORT
CONEHATTA
PUBLIC WATER SYSTEM

Important Drinking Water Definitions	
MPL	MPL: State Assigned Maximum Permissible Level
For more information please contact:	

Contact Name: Ricky Cook
Address: P.O. Box 6366, Choctaw, MS 39350
Phone: 601-650-1760